



For cable sizes refer to Specification Appendix 14/4

HIGHWAY WORKS DETAILS

Notes :-

1. Incase of concrete columns a door earth shall be provided for an S.N.E supply but not for a Protective Multiple Earthing supply.
2. All equipment to be fixed to backboard using brass screws.
3. To be read in conjunction with Standard Detail Sheets HW/14.02 & HW/14.06 to HW/14.08.



SCHEME  
STANDARD DETAIL SHEETS



DRAWING  
TYPICAL BASE COMPARTMENT  
EQUIPMENT LAYOUT

This detail is controlled by Birmingham City Council. Email - Transport.Projects@Birmingham.gov.uk

DATE	REV.	DESIGNER	PM	DRN	PM	REVISION
2013	B	DETAILS & FRAME AMENDED		DH		PP
2010	A	NOTES AMENDED		CCH		MM
2007	-	ORIGINAL DRAWING CREATED		NDM		BSF

GENERAL

DWG. No  
HW/14.15

SCALE  
NTS